

Emission Testing Report Summary

Report Number 004635 by Ektimo on 09/08/2017

Ektimo was engaged by Astron Sustainability to determine emissions to air from the Afterburner Discharge Stack at the Seven Hills plant.

Monitoring point	Parameter	Licence limits (mg/m ³)	Detected values (mg/m ³)
Afterburner discharge stack	Dioxins and furans	0.1	0.0037
	Hydrogen sulphide	5	<0.1
	Volatile organic compounds	40	6.3
	Nitrogen oxides	2000	330
	Mercury	3	<0.004
	Chlorine	200	<0.1
	Cadmium	3	<0.009
	Hydrochloric acid	400	6.6
	Total Fluoride	50	<0.3
	Solid particles	250	53
	Sulfuric acid mist and sulphur trioxide	100	5.3
	Type 1 substances	10	≤0.54

This satisfies the annual testing requirement for 2017 as prescribed in Environment Protection Licence 124.

If you would like to report a pollution incident or to raise/ escalate a matters concerning pollution management, please contact our office on (02) 9854 2700.

Astron Sustainability / VIP Drum Reconditioners, Seven Hills

30-32 Powers Road
Seven Hills, NSW 2147
P. (02) 9854 2700
F. (02) 6100 9770

www.vippackaging.com.au